


MONTHLY FIRE EXTINGUISHER INSPECTION

1. Check accessibility

- Extinguisher should be easily visible.
- It should not be blocked by any objects.
- It should be secured inside a cabinet or to the wall.



2. Examine

- Serial number and label should be legible.
- Extinguisher should be free of corrosion dents, and other signs of damage.
- Hose should not have any cracks.
- Locking pin should be intact.

3. Pressure Gauge

- The gauge needle should be within the green area.

4. Inspection Tag

- Tag should show the last inspection date.
- Sign your initials by the correct month.
- Fill in current condition with OK or Service.
- Submit Facilio Request for any that require service and include a photo showing location, size/type.